

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/02/2013
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 15C0001158		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 - ST VINCENT SURGERY CENTER OF TERRE HAUTE B. WING _____		(X3) DATE SURVEY COMPLETED R 02/19/2013	
NAME OF PROVIDER OR SUPPLIER ST VINCENT SURGERY CENTER OF TERRE HAUTE				STREET ADDRESS, CITY, STATE, ZIP CODE 227 E MCCALLISTER DR TERRE HAUTE, IN 47802			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	INITIAL COMMENTS Paper compliance to the Life Safety Code Recertification Survey conducted on 02/07/13 was completed on 02/19/13. Review Date: 02/19/13 Facility Number: 005650 Provider Number: 15C0001158 AIM Number: NA Surveyor: Dennis Austill, Life Safety Code Supervisor St. Vincent Surgery Center of Terre Haute was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 Edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 20, New Ambulatory Health Care Occupancies.			{K 000}			
{K 050}	416.44(b)(1) LIFE SAFETY CODE STANDARD Fire drills are held at unexpected times under varying conditions, at least quarterly on each shift. The staff is familiar with procedures and is aware that drills are part of established routine. 20.7.1.2, 21.7.1.2 This STANDARD is not met as evidenced by:			{K 050}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.